


# CERTIFICATE

Certified Passive House Component

Component-ID 0611wi03 valid until 31st December 2016

Passive House Institute  
Dr. Wolfgang Feist  
64283 Darmstadt  
Germany




Category: **Window frame**  
Manufacturer: **Viking Window AS,  
Järvamaa,  
Estonia**  
Product name: **Viking SW 14 Aluclad Passive**

**This certificate was awarded based on the following  
criteria for the cool, temperate climate zone**

Comfort  $U_W = 0.80 \leq 0.80 \text{ W/(m}^2 \text{ K)}$   
 $U_{W, \text{ installed}} \leq 0.85 \text{ W/(m}^2 \text{ K)}$   
mit  $U_g = 0.70 \text{ W/(m}^2 \text{ K)}$

Hygiene  $f_{Rsi=0.25} \geq 0.70$



Passive House  
efficiency class

phE

phD

phC

phB

phA


[www.passivehouse.com](http://www.passivehouse.com)

cool, temperate climate



**CERTIFIED  
COMPONENT**

Passive House Institute



## Description

Timberframe (0.11 W/(mK)) with aluminium facing shell. Pane thickness: 50 mm (4/18/4/20/4), Re-bate depth: 16 mm.

## Explanation






The window U-values were calculated for the test window size of 1.23 m × 1.48 m with  $U_g = 0.70$  W/(m<sup>2</sup> K). If a higher quality glazing is used, the window U-values will improve as follows:

Glazing	$U_g =$	0.70	0.64	0.58	0.54	W/(m <sup>2</sup> K)
		↓	↓	↓	↓	
Window	$U_w =$	0.80	0.76	0.71	0.68	W/(m <sup>2</sup> K)




Transparent building components are classified into efficiency classes depending on the heat losses through the opaque part. The frame U-Values, frame widths, thermal bridges at the glazing edge, and the glazing edge lengths are included in these heat losses. A more detailed report of the calculations performed in the context of certification is available from the manufacturer.

The Passive House Institute has defined international component criteria for seven climate zones. In principle, components which have been certified for climate zones with higher requirements may also be used in climates with less stringent requirements. In a particular climate zone it may make sense to use a component of a higher thermal quality which has been certified for a climate zone with more stringent requirements.

Further information relating to certification can be found on [www.passivehouse.com](http://www.passivehouse.com) and [passipedia.org](http://passipedia.org).

Frame values		Frame width $b_f$ mm	U-value frame $U_f$ W/(m K)	$\Psi$ -glass edge $\Psi_g$ W/(m <sup>2</sup> K)	Temp. Factor $f_{Rsi=0.25}$ [-]
Top		102	0.86	0.022	0.72
Left		102	0.86	0.022	0.72
Right		102	0.86	0.022	0.72
Bottom		102	0.83	0.023	0.72
Mullion		190	0.86	0.022	0.72
Spacer: SWISSPACER Ultimate			Secondary seal: Polysulfide		

## Validated installations

Insulated formwork blocks		Timber frame		EIFS	
					
$\Psi_{\text{install}}$	W/(m K)	$\Psi_{\text{install}}$	W/(m K)	$\Psi_{\text{install}}$	W/(m K)
Top	0.009	Top	0.016	Top	0.010
Left	0.009	Left	0.016	Left	0.010
Right	0.009	Right	0.016	Right	0.010
Bottom	0.020	Bottom	0.022	Bottom	0.021
$U_{W,\text{installed}} = 0.83 \text{ W/(m}^2 \text{ K)}$		$U_{W,\text{installed}} = 0.85 \text{ W/(m}^2 \text{ K)}$		$U_{W,\text{installed}} = 0.83 \text{ W/(m}^2 \text{ K)}$	

